



Grid 1 Results - Horizontal Illuminance (lux) Eav= 8.76 Emin= 1.54 Emax= 21.05 Emin/Emax= 0.07 Emin/Eav= 0.18 Emax/Eav= 2.40	Grid 6 Results - Horizontal Illuminance (lux) Eav= 11.21 Emin= 4.48 Emax= 20.07 Emin/Emax= 0.22 Emin/Eav= 0.40 Emax/Eav= 1.79
Grid 2 Results - Horizontal Illuminance (lux) Eav= 8.30 Emin= 1.55 Emax= 18.28 Emin/Emax= 0.08 Emin/Eav= 0.19 Emax/Eav= 2.20	Grid 7 Results - Horizontal Illuminance (lux) Eav= 10.32 Emin= 4.19 Emax= 24.61 Emin/Emax= 0.17 Emin/Eav= 0.41 Emax/Eav= 2.38
Grid 3 Results - Horizontal Illuminance (lux) Eav= 10.18 Emin= 2.04 Emax= 30.34 Emin/Emax= 0.07 Emin/Eav= 0.20 Emax/Eav= 2.98	Grid 8 Results - Horizontal Illuminance (lux) Eav= 10.37 Emin= 4.29 Emax= 20.02 Emin/Emax= 0.21 Emin/Eav= 0.41 Emax/Eav= 1.93
Grid 4 Results - Horizontal Illuminance (lux) Eav= 7.88 Emin= 2.44 Emax= 15.80 Emin/Emax= 0.15 Emin/Eav= 0.31 Emax/Eav= 2.00	Grid 9 Results - Horizontal Illuminance (lux) Eav= 11.39 Emin= 5.29 Emax= 21.70 Emin/Emax= 0.24 Emin/Eav= 0.46 Emax/Eav= 1.90
Grid 5 Results - Horizontal Illuminance (lux) Eav= 8.40 Emin= 2.27 Emax= 22.76 Emin/Emax= 0.10 Emin/Eav= 0.27 Emax/Eav= 2.71	
Luminaire Data Luminaire A BGP291 DRXN1 Luminaire B BGP291 DX51 Luminaire C BGP291 DW50 Luminaire D BGP292 DW50 Luminaire E BGP292 DX50 Luminaire F BGP292 DX51 Luminaire G BGP100 FCC DS LED50/-NO	

- Key
- Luminaire A Column
 - Luminaire B Column
 - Luminaire C Column
 - Luminaire D Column
 - Luminaire E Column
 - Luminaire F Column
 - Luminaire G Column
 - Beam Aiming Target
 - Photometric Centre

All Dimensions in metres



Project Name
**OLDCOURT ROAD,
BALLYCULLEN**

Drawing Name
**PROPOSED LIGHTING
LAYOUT**

Notes:

- Unless agreed otherwise, the lighting proposal produced by the Lighting Application Specialist (LIAS) team of Philips Lighting UK&I is not intended for construction purposes, as it does not take into account the elimination of health and safety risks at this stage. For further details please refer to sheet number **DWG 00**
- Do not scale for this drawing

PROPOSAL
(NOT FOR CONSTRUCTION)

Rev	DSR no.	Comment	Date	LIAS	KAM
0	D-584671	INITIAL PROPOSAL	20.08.24	CP	SC

Project Number
0401022094

Scale & Sheet Size
1:500 @ A0

Sheet No
DWG 02